

- (d) (i) 1 year.
(ii) 5 years.

ER 46 (2)(e), (g)
(2 marks)

- (e) • The Secretary
• The owner or occupier of the property.

ER 50
(2 marks)

- (f) (i) Yes. By failing to properly certify the work under regulation 39.
Regulation 51(b)

(1 mark)

- (ii) A fine not exceeding \$10,000.

ER 51(a)
(1 mark)

- (g) None, Ref. AS/NZS 3000: Tables 3.6 and 3.7

(2 marks)

- (h) Any TWO of:

- Must be multi-stranded insulated or sheathed
- Have not less than seven strands
- Have a cross-sectional area of not less than 1 mm²

AS/NZS 3001: 3.4.1
(2 marks)

(i)
$$\begin{aligned} \text{Isc} &= \frac{230}{0.38} \\ &= 605.26 \text{ A} \end{aligned}$$

GK
(2 marks)

- (j) The power factor.

GK
(2 marks)

Question 2

(a) Regulation %

$$= \frac{V1 - V2}{V1} \times \frac{100}{1}$$

$$= \frac{400 - 387}{400} \times \frac{100}{1}$$

$$= 3.25\%$$

(½ mark)

(1 mark)

Fault MVA rating of busbars

$$= \frac{400000}{0.0325}$$

$$= 12.31 \text{ MVA}$$

(½ mark)

(1 mark)

GK

Prospective short circuit current

$$= \frac{\text{MVA} \times 10^6}{\sqrt{3} \times V_L}$$

$$= \frac{1231000}{\sqrt{3} \times V_L}$$

$$= 17.77 \text{ kA}$$

(½ mark)

(½ mark)

(1 mark)

(b) (i) The current reduces

(1 mark)

(ii) The overloads need to be set to running current values.

(1 mark)

(c) Any TWO of

- To ensure the protection can clear the fault current
- To ensure the protection operates within the required time.
- To ensure equipment can carry the prospective short circuit current without damage.

(2 marks)

GK

(d) 4mm² Copper (Cu)

AS/NZS 3000: 5.8.3.2(a)
(1 mark)

Question 3

- (a) • Neutral current out of balance with the phase current. (1 mark)
- A magnetic field is induced into the iron core. (1 mark)
- The induced magnetic field induces a current in the sensing coil (1 mark)
- The tripping coil is energised, isolating the circuit (1 mark)
- (b) (i) A Type A RCD (½ mark)
- (ii) • It has a residual operating current of 30 mA or less.
• Provides protection against residual alternating current
• Provides protection against a residual pulsating direct current. (1½ marks)
- GK
- (c) Any TWO of:
- Install an SRCD on the first socket outlet on the final subcircuit and protect all socket outlets downstream with the SRCD
 - Install an SRCD on the first socket outlet in the kitchen and protect the other socket outlets from this outlet.
 - Install SRCDs on each socket outlet
- AS/NZS 3000: 2.5.3.4
GK
(4 marks)

Question 4

(a) Loading

<u>Buried direct</u>	<u>Surface mounted (touching)</u>	
From Table 12, column 14, rating of 10 mm ² is 81A	From Table 12, column 4, rating of 16 mm ² is 78A	(½ mark)
From Table 27(2) the derating factor is 1	From Tables 27(2) the derating factor is 0.94	(½ mark)
$I_{\max} = 81 \times 1$ $= 81A$	$I_{\max} = 78 \times 0.94$ $= 73.32A$	(½ mark)
Based on loading, a 10 mm ² cable buried direct is suitable.	Based on loading, a 16 mm ² cable surface mounted is suitable	(1 mark)

(b) Volt drop - Maximum volt drop permitted is:

Mains	$400 \times 0.02 = 8$ volts	(1 mark)
Sub-circuit	$392 \times 0.015 = 5.88$ volts	(1 mark)

<u>Buried direct</u>	<u>Surface mounted (touching)</u>	
From Table 42, $V_d/A.m = 3.86$ for 10 mm ² cable	From Table 42, $V_d/A.m = 2.43$ for 16 mm ² cable	(½ mark)
$V_d = \frac{V_d/A.m \times I \times L}{1000}$	$V_d = \frac{V_d/A.m \times I \times L}{1000}$	(½ mark)
$= \frac{3.86 \times 63.75 \times 45}{1000}$	$= \frac{2.43 \times 63.75 \times 45}{1000}$	(1 mark)
$= 11.07$ V	$= 6.97$ V	(1 mark)

(c) (i) From Table 42, $V_d/A.m = 1.54$ for 25 mm² cable

$$\text{Volt drop} = \frac{V_d/A.m \times I \times L}{1000}$$

$$= \frac{1.54 \times 63.75 \times 45}{1000}$$

$$= 4.42 \text{ V}$$

(1/2 mark)

(1 mark)

Therefore, a 25 mm² cable is the minimum size of cable that meets the load and volt drop requirements.

(1/2 mark)

(ii) The cable can be surface mounted or buried direct.

(1/2 mark)


Question 5

(a) Any TWO of:

- Any metal not normally live could be live at up to 230V.
- If the earth fault path is of high impedance the main fuse may not blow
- The main switch does not isolate the incoming supply for the installation.
- A fire hazard could exist at any high resistance joint in the MEN system or if the neutral bar insulation is inadequate.
- An electrical worker interrupting the MEN circuit (including work on the earth bar, neutral bar or MEN link) is vulnerable.
- The main neutral is being switched.
- A standard isolation test will not identify that the neutral is connected to the incoming phase.

(2 marks)

(b) (i)



- A-B. Shows a test between neutral bar to a remote earth with a voltmeter.
- C-D. Shows a test between the supply side of main switch to a remote earth with a voltmeter

(2 marks)

(ii) Using the voltmeter, remote earth and trailing lead.

- Take a voltage test between the supply side of the main switch and the remote earth. (1 mark)
- Take a voltage test between the earth/neutral bar and the remote earth. (1 mark)

(iii) If no transposition has taken place:

- The reading at the main switch should be about 230 V (½ mark)
- The reading at the neutral/earth bar should be about 0 V. (½ mark)

(iv) If a transposition has taken place:

- The reading at the main switch should be about 0 V (½ mark)
- The reading at the neutral/earth bar should be about 230 V. (½ mark)

Note: The removal of the MEN link with the installation live is hazardous.

(c) Any TWO of:

- The main neutral in the house is open-circuited (or high resistance)
- The main distribution neutral is open-circuited (or high resistance)
- The earth at the distribution transformer is open-circuited (or high resistance)
- There is a voltage rise in the installation earthing system
- Spread earth pin on the socket outlet
- Faulty high resistance earth lead and an earth fault on the appliance ie washing machine

(or any other explanation that results in a high impedance neutral)

(2 marks)

Question 6

- (a) (i) Must be installed and maintained so that they operate safely if used for their intended purpose.

ER 98 (1)
(1 mark)

- (ii) Must have a rating that does not exceed the rating of the socket-outlet.

ER 98 (4)
(1 mark)

- (b)
- Through a shore-mounted isolating transformers with the hull of metallic-hulled pleasure craft and conductive parts bonded together in accordance with Clause 4.3.1.
 - Through an on-board isolating transformers with the hull of metallic-hulled pleasure craft and conductive parts bonded together in accordance with Clause 4.3.2.
 - Connection without an isolating transformer in accordance with clause 4.3.3.

AS/NZS 3004: 1.8
(3 marks)

- (c)
- Must comply with IEC 60309-2 (round pin)
 - Rated at not less than 16 A
 - Outlets rated at 32A or more shall be arranged to prevent the removal of the plug when energised.

AS/NZS 3004: 2.4.2.4.2
(3 marks)

- (d) Any ONE of:

- MCBs
- Fully enclosed neutral links.

GK
(2 marks)

Question 7

- (a) (i) Cables show no undue evidence of insulation or sheath deterioration.
NZS 3019: 5.1(a)
(1 mark)
- (ii) • Switchboard and electrical equipment have no conductor insulation deterioration.
NZS 3019: 5.1(f)
- MCBs, fuses and switches show no evidence of mechanical damage.
NZS 3019: 5.1(g)
- Semi-enclosed rewirable fuses have not deteriorated due to arcing and have no exposed live parts when the removable part of the fuse fitting is fitted into the base.
NZS 3019: 5.1(h)
- Switchboard equipment is correctly labelled.
NZS 3019: 5.1(i)
(4 marks)
- (iii) Covers of fixed-wired appliances are not broken or missing, giving access to live parts or basic insulation
NZS 3019: 5.1(j)
(1 mark)
- (b) • Ensure that the polarity and phase rotation of the supply is correct
- Ensure that the protection of the supply is correctly rated
- Verify the safety of revenue meters and associated load control fittings of mains
- Verify that there is a main earthing system, if the supply is from a MEN system.
ER43A(c),(d),(e),(f)
(4 marks)

Question 8

(a) (i) Any FOUR of:

- (1) Touch voltage in flats may rise to dangerous levels
- (2) High current flow in main earth conductor
- (3) Rise in the supply voltage
- (4) Unstable supply voltage
- (5) Current flow through the MEN system of adjacent installations

GK
(2 marks)

(ii) ONE danger associated with (i)


- (1) ● Shock hazard
- (2) ● Fire hazard
● Shock hazard
- (3) ● Equipment damage
● Fire hazard
● Shock hazard
- (4) ● Fire hazard
● Shock hazard
- (5) ● Fire hazard
● Shock hazard

GK
(2 marks)

- (b) ● Where the metal is not fully isolated from earth
● Where the metal is located within arms reach.

ER 84(2)
(2 marks)

(c) Figure B4.1 MEN system (simplified) showing fault (Ia) path



The path showing:

- From the fault through the protective earthing conductor, (PE), main earthing terminal bar and MEN link. (1 mark)
- The neutral-return path, consisting of the neutral conductor, (N), between the main neutral terminal or bar and the neutral point at the transformer. (1 mark)
- The path through the neutral point of the transformer and the transformer winding. (1 mark)
- The active conductor as far as the point of the fault. (1 mark)

AS/NZS 3000: Appendix B4.3
(4 marks)

Question 9

Living Units Calculation

Load Group	Calculation	Load (A)	
<u>Group A</u>			
Lighting	$5 + (18 \times 0.25)$	9.50	(½ mark)
<u>Group B</u>			
Socket outlets	$15 + (18 \times 3.75)$	82.50	(½ mark)
<u>Group C</u>			
Ovens	18×2.8	50.40	(1 mark)
Hobs	10×2.8	28.00	
<u>Group E</u>			
Instantaneous hot water	8×6	48.00	(½ mark)
<u>Group F</u>			
Storage water heaters	4×6	24.00	(½ mark)
Total		242.40	(1 mark)

Communal Areas Calculation

Load Group	Calculation	Load (A)	
<u>Group H</u>			
Lighting	$(6000 \div 3) \div 230$	8.7	(1 mark)
<u>Group I</u>			
Socket outlets	$4 \times 2 = 8A$ (highest phase, column 4)	8.00	(½ mark)
<u>Group J(i)</u>			
(i) Clothes dryer	$20000 \div 3 = 6666.67W$ $6666.67 \div 230 = 28.99A$ $28.99 \div 0.5 = 14.5A$	14.5	(1 mark)
(ii) Hot water cylinders	$(6000 \div 3) \div 230 = 8.7A$ $8.7 \div 0.5$	4.35	
<u>Group J(iii)</u>			
Spa pools	17.39×0.75	17.39	(1 mark)
	17.39×0.25		
<u>Group L</u>			
Water pump		10.8	(½ mark)
Total		63.74	(1 mark)

Load of heaviest loaded phase = 306.14A

(1 mark)