



VC No:

**INSTALLATION DETAILS**

Client:	Address of installation (to which this certificate refers):	Postcode
---------	--	----------

**THIS CERTIFICATE COVERS VERIFICATION OF:**

- An existing electrical installation following disconnection from supply for greater than 6 months Reg 74 (Electrical inspector)
- An existing installation of a caravan park in accordance with Reg 75 & AS/NZS 3001:2008 (Electrical Inspector)
- An existing installation of a boat marina in accordance with Reg 75 & AS/NZS 3004.1:2008 (Electrical Inspector)
- An existing installation on which no work has been carried out and is not subject to Regulation 73
- An MEN system of installation
- Existing Mains work

**DETAILS OF INSTALLATION VERIFICATION:**

**NOTE:**

The COV does not satisfy the obligations under regulation 66(1)(a) if the person carries out prescribed electrical work, to have the work certified. Also refer Reg 71(3) (a) (b) (c) Inspection of Prescribed Electrical Work & 74(3) Reconnection or restoring supply to certain low voltage installations.

**CERTIFICATION:**

I have carried out a Verification of the above installation in accordance with AS/NZS 3019:2007 and I certify the installation meets the requirements detailed in section 3, 4 or 5 of AS/NZS Standard for the issue of a Certificate of Verification.

AS/NZS 3019: 2007 in accordance with                      Section 3                      Section 4                      Section 5

Name (name person who carried out the verification):

Registration Class and Number:

Signature:

Date:

/                      /



VC No:

**INSTALLATION DETAILS**

Client:	Address of installation (to which this certificate refers):	Postcode
---------	--	----------

**THIS CERTIFICATE COVERS VERIFICATION OF:**

- An existing electrical installation following disconnection from supply for greater than 6 months Reg 74 (Electrical inspector)
- An existing installation of a caravan park in accordance with Reg 75 & AS/NZS 3001:2008 (Electrical Inspector)
- An existing installation of a boat marina in accordance with Reg 75 & AS/NZS 3004.1:2008 (Electrical Inspector)
- An existing installation on which no work has been carried out and is not subject to Regulation 73
- An MEN system of installation
- Existing Mains work

**DETAILS OF INSTALLATION VERIFICATION:**

**NOTE:**

The COV does not satisfy the obligations under regulation 66(1)(a) if the person carries out prescribed electrical work, to have the work certified. Also refer Reg 71(3) (a) (b) (c) Inspection of Prescribed Electrical Work & 74(3) Reconnection or restoring supply to certain low voltage installations.

**CERTIFICATION:**

I have carried out a Verification of the above installation in accordance with AS/NZS 3019:2007 and I certify the installation meets the requirements detailed in section 3, 4 or 5 of AS/NZS Standard for the issue of a Certificate of Verification.

AS/NZS 3019: 2007 in accordance with                      Section 3                      Section 4                      Section 5

Name (name person who carried out the verification):

Registration Class and Number:

Signature:

Date:

/                      /

## CONNECTION / RECONNECTION / FINAL CONNECTION / ENLIVENING VERIFICATION

Installation compatible with supply system				Address			
Installation last disconnected / isolated for 6 months or more apply Regulation 73(2)(5) <b>OR</b> this is an Independent Inspection for property owner <b>OR</b> other				PostCode			
Was New PEW carried out on installation – Reg 67(1) (2) on mains <b>OR</b> other I have sighted COC COC No:				Where Inspection required, by others (Reg 70) I have verified inspection completed on COC COC No:			
DOC Installation On COC Other							
CHECKS	LOCATION	VISUAL	INSULATION / RES RESULTS	IF SUPPLY IS MEN EARTHING SYSTEM PRESENT	POLARITY OF SUPPLY CORRECT	MULTI PHASE CORRECT	PROTECTION OF SUPPLY ROTATION CORRECT CORRECTLY RATED
Mains	O/H U/G						
MEN							
Main Earth							
Verification by:			Date: / /		Network Co / Contractor:		
Registration No:							
Meter Installer Safety check / test or Company / EMP Licence:		DOC available	Date: / /	Signature:		Registration No:	
Smart Meter installed ICP No:				<div></div>		Retailer:	
Final connection by:			Date: / /		Network Co / Contractor:		
Registration No:			Time: :				
Enlivened by:			Date: / /		Network Co / Contractor:		
Registration No:			Time: :				
Comments							



**Electrical Workers  
Registration Board**  
SAFETY | COMPETENCY | COMPLIANCE

VC No:

**Certificate of  
Verification**

## CONNECTION / RECONNECTION / FINAL CONNECTION / ENLIVENING VERIFICATION

Installation compatible with supply system				Address			
Installation last disconnected / isolated for 6 months or more apply Regulation 73(2)(5) <b>OR</b> this is an Independent Inspection for property owner <b>OR</b> other				PostCode			
Was New PEW carried out on installation – Reg 67(1) (2) on mains <b>OR</b> other I have sighted COC COC No:				Where Inspection required, by others (Reg 70) I have verified inspection completed on COC COC No:			
DOC Installation On COC Other							
CHECKS	LOCATION	VISUAL	INSULATION / RES RESULTS	IF SUPPLY IS MEN EARTHING SYSTEM PRESENT	POLARITY OF SUPPLY CORRECT	MULTI PHASE CORRECT	PROTECTION OF SUPPLY ROTATION CORRECT CORRECTLY RATED
Mains	O/H U/G						
MEN							
Main Earth							
Verification by:			Date:	/	/	Network Co / Contractor:	
Registration No:							
Meter Installer Safety check / test or Company / EMP Licence:		DOC available	Date:	/	/	Signature:	
Smart Meter installed ICP No:						Registration No:	
						Retailer:	
Final connection by:			Date:	/	/	Network Co / Contractor:	
Registration No:			Time:	:			
Enlivened by:			Date:	/	/	Network Co / Contractor:	
Registration No:			Time:	:			
Comments							



**Electrical Workers  
Registration Board**  
SAFETY | COMPETENCY | COMPLIANCE

VC No:

**Certificate of  
Verification**